

Office of the Electricity Department,
Thrissur Corporation, Thrissur,
Date: 04.08.2015

E5 – 8959/14/Group-V/Transformers

THRISSUR CORPORATION – ELECTRICITY DEPARTMENT

RE - TENDER NOTICE

Sealed super scribed Tenders are invited for the supply of the following items for the use of Electricity Department, Thrissur Corporation, so as to reach the undersigned on or before 2 PM on 11.9.2015 (Including Postal). The tender form will be available upto 1 pm on the same day. The Tender will be opened at 3 PM on the same day in the presence of available Tenderers. If this day happens to be a holiday, the next working day will be operative for the same purpose. The cover containing the Tender should be super scribed as **Tender for the supply of " Group V – Transformers "**

Group V – Transformers & Transformer Oil

Cost of tender form: Rs. 9500/- + S.T (Rs.100 postal charge)

E M D : Rs. 62,830/-

Security Deposit : 5%

Group	Sl No	Item	Unit	Specification	Qty
V	1	Transformer 160 KVA	No	160 KVA, 11KV/433V, 3 phase, 50Hz, Copper wound transformer with tappings +5% to -5% in steps of 2.5% and with Bushings on HT side and on LT side. 4 nos suitable size copper strips with adequate size holes for connecting the lead wires on LT side, Breather with clear view type of best quality and earthing bolt of size 1x5/8" with necessary brass washers at the transformer base, dimetrically on opposite sides, shall also be provided.	2
V	2	160 KVA Cable entry type Outdoor Transformer	No.	160 KVA, 11kV/433V, 3ph, 50 Hz, outdoor type, ONAN Cooled, Copper wound Distribution Transformer with first fill of oil, Cable Box on HT & LT sides, Off circuit tapping of +5% to -5% in steps of 2.5% and standard fittings conforming to IS 2026/77.	4
V	3	250 KVA cable entry Type Outdoor Transformer	No.	250 KVA, 11kV/433V, 3ph, 50 Hz, outdoor type, ONAN Cooled, Copper wound Distribution Transformer with first fill of oil, Cable Box on HT & LT sides, Off circuit tapping of +5% to -5% in steps of 2.5% and standard fittings conforming to IS 2026/77.	7

V	4	315 KVA Cable entry type Transformer	No.	315 KVA, 11kV/433V, 3ph, 50 Hz, outdoor type, ONAN Cooled, Copper wound Distribution Transformer with first fill of oil, Cable Box on HT & LT sides, Off circuit taping of +5% to -5% in steps of 2.5% and standard fittings conforming to IS 2026/77.	2
V	5	500 KVA Cable entry type Transformer	No.	500 KVA, 11kV/433V, 3ph, 50 Hz, outdoor type, ONAN Cooled, Copper wound Distribution Transformer with first fill of oil, Cable Box on HT & LT sides, Off circuit taping of +5% to -5% in steps of 2.5% and standard fittings conforming to IS 2026/77.	2
V	6	Transformer Oil	Ltr	Mineral Insulating oil for using in Transformers as per ISS : 335 of 1985 (Transformer Oil) & Test certificate should be produced along with supply.	2200

Guarantee/Warranty period, Make/ Brand Name, and other terms and conditions, if any, in this regard must be clearly mentioned in the Tender. The rate quoted should have minimum three months validity period and it should be inclusive of all taxes and other expenses. The materials should be delivered at our stores. Tender without remitting the cost of tender form and E M D will not be considered. The E M D can be paid by cash or D D drawn in favour of Assistant Secretary, Electricity Department, Thrissur Corporation. The undersigned reserves the right to accept or reject the tender without assigning any reason. The successful tenderer should remit 5% Security Deposit including Earnest Money Deposit. Further details can be had from the office during working hours.


ASSISTANT SECRETARY.