

1000



# THRISSUR CORPORATION ELECTRICITY DEPARTMENT

## Test Report of Applicant's Installation

(To be filled by authorised employee of TCED)

(See Regulation 77(4) of the Kerala Electricity Supply Code, 2014)

Reference No. : \_\_\_\_\_

Date \_\_\_\_\_

### Result of Insulation Resistance Test

(To be measured on applying a potential of 500 volts for one minute between phase conductor and earth) :

	Phase-1 & Earth	Phase - 2 & Earth	Phase - 3 & Earth
Between Phase and Earth	_____	_____	_____

**(Caution :** Insulation Resistance between phase and neutral or between phases shall not be measured when any of consumer's appliances, such as fans, tubes, bulbs etc. is in circuit as result of such test would give resistance of appliance and not the insulation resistance of installation)

Certified that an Earth Terminal as required under the Central Electricity Authority Regulations has been provided by the TCED and this terminal has been connected with the earthing system of TCED.

The following deficiencies have been found in the electrical installation. The consumer is requested to remove them within 10 days i.e. by ..... and inform this office, failing which the request for new connection would lapse:

- 1 \_\_\_\_\_
- 2 \_\_\_\_\_
- 3 \_\_\_\_\_

Date : \_\_\_\_\_

Signature / Seal of TCED representative :

Name and Designation :

(To be filled by applicant)

The testing of the premises has been carried out by TCED in my presence and :

I am satisfied with the testing / I am not satisfied with the testing and may file an appeal with CGRF.

(Strike out whichever is not applicable)

It is also certified that the TCED has / has not provided (Strike out whichever is not applicable) an Earth Terminal as per Central Electricity Authority Regulations at the premises and this earth terminal has / has not (Strike out whichever is not applicable) been connected to the earthing system of TCED.

Signature and Name of applicant

Address of applicant :